



BYELAWS FOR USE OF LPG CYLINDER & GEYSERS

LPG includes propane, butane, and butylene's used for heating, cooking, and fuel. The purpose of this SOP is to provide safe practices for use and storage of portable LPG cylinders. This SOP is based on OGRA requirements. Permission certificate to be submitted in Building Control Section of DHA Bahawalpur. Approval will be granted subject to fulfillment of following conditions in totality:-

1. **"Permission Certificate for use of LPG Cylinder"** (Document reference 4812037) will be submitted by respective villa/ house owner.
2. **Safety Standards.** LPG cylinders and geysers must meet specific safety standards to prevent accidents and ensure safe usage. This can be ensured through regular inspections, installation by licensed professionals and compliance with relevant safety codes and standards.
3. **Location.** LPG cylinders should be stored in a safe and secure locations away from direct sunlight, heat sources and ignition sources. They should also be kept in a well ventilated area, preferably outdoor and away from source of potential damage such as vehicles or heavy equipment. Geysers should be installed in a secure and well ventilated area, preferably in a separate room or closet.
4. **Capacity.** Small/ medium size of LPG cylinders are permitted for use in residential/ commercial units. This can help to prevent the storage of excessively large cylinders that may pose a greater risk of fire or explosion. Excessive usage can be compensated by frequent repetition /replacement of medium size LPG cylinder.
5. **Installation and Maintenance.** LPG cylinders and geysers be installed and maintained by licensed professionals. This can help to ensure that all installations are safe and compliant with local regulations.
6. **Use and Operations.** Following guidelines should be enforced for usage of LPG cylinders and geysers installed for residential / commercial usage:-
 - a. Turn off the gas supply when gadgets are not in use.
 - b. Not smoking near LPG cylinders.
 - c. Avoiding use of electrical equipment near geysers.
7. **Reporting of Accident.** It is expected from respective owner (residential/ commercial) to report of any accident or incidents involving LPG cylinders or geysers to the appropriate authorities. This will help to improve safety standards and prevent future accidents.

NOTE All the residents are requested to regularize their case by adoption/ adaption to above referred byelaws latest by **15 March 2023**. Failing which penalties in the form of imposition of fine shall be materialized.



PERMISSION CERTIFICATE FOR USE OF LPG CYLINDERS

- COMPANY

It is certified that Mr/ Mrs / Ms _____ S/O

D/OW/O of _____ Owner of Building No. _____ Sector _____

Phase _____ DHA Bahawalpur, is allowed to use LPG cylinders provided by our company for running of restaurant. Gas infrastructure layout in the building, cylinders being used and their placing is as per safety procedures governed by Oil Gas Regulating Authority (OGRA).

Inspector Name: _____

Designation in Company: _____

Dated: _____

Company Stamp: _____

Note: This is a standard specimen certificate. Please get NOC of your concerned company from whom you have purchase LPG Cylinders.